

Messbereichsvergleich WP , WS , Einstrahl , Ultraschall



Typ	Anlauf	Q1	Q2	Q3	Q4	Überlast (CutOff)
P.FOX WP DN50	0,15	0,4	0,64	40	50	55
P.FOX WS DN50	0,09	0,31	0,5	25	31,25	35
P.JET DN50	0,025	0,079	0,127	25	31,25	40
OCTAVE DN50	0,015	0,08	0,125	40	50	60

